

SV setting & Monitor mode

Symbol	Name	The display or data ranges	Factory set value
—	Measured value (PV)/ Set value (SV) monitor	PV display: PV is displayed. Input scale low to Input scale high SV display: The target value for control is displayed. <ul style="list-style-type: none"> SV Remote setting (RS) input value Manual manipulated output value 	—
SV	Set value (SV) ¹	Setting limiter low to Setting limiter high The target value for control can be set.	0
CT1	Current transformer 1 (CT1) input value monitor	0.0 to 30.0 A or 0.0 to 100.0 A Displayed only when the CT1 input is provided.	—
CT2	Current transformer 2 (CT2) input value monitor	0.0 to 30.0 A or 0.0 to 100.0 A Displayed only when the CT2 input is provided.	—
SR	Remote setting (RS) input value monitor	Setting limiter low to Setting limiter high The Remote setting (RS) input value is displayed.	—
EHn1	Event monitor 1	<p>It is possible to check the type of created event depending on which digit was lit. Displayed when the event action is selected for any one of the Event types from 1 to 4.</p>	—
EHn2	Event monitor 2	<p>It is possible to check the type of HBA which occurred depending on which digit was lit. Display when the CT1 or CT2 input is provided. This screen is not displayed when set the CT assignment to "0: None."</p>	—
MV1	Manipulated output value (MV1) monitor [heat-side]	PID control or Heat/Cool PID control: MV1 is displayed. (-5.0 to +105.0%) Position proportioning PID control. When the control motor with Feedback resistance (FBR) is used: FBR input value is displayed. (0.0 to 100.0%)	—
MV2	Manipulated output value (MV2) monitor [cool-side]	-5.0 to +105.0% MV2 of cool-side is displayed when the control action is Heat/Cool PID control.	—
RA	Memory area soak time monitor	0 minutes 00 seconds to 199 minutes 59 seconds or 0 hours 00 minutes to 99 hours 59 minutes Memory area soak time is displayed when the Ramp/Soak control is being executed.	—
RE	Memory area transfer	1 to 8 This screen is displayed in SV setting & monitor mode when the direct key type is type 2.	1
PSn	Manipulated output value at MV transfer	PID control: Output limiter low (MV1) to Output limiter high (MV1) (-5.0 to +105.0%) Heat/Cool PID control: -Output limiter high (MV2) to +Output limiter high (MV1) (-105.0 to +105.0%) When in Auto mode, Manipulated output values (MV1 and MV2) can be manually changed. This screen is not displayed when set the MV transfer function to "0."	0.0
ILR	Interlock release	on: Interlock oFF: Interlock release Not displayed when Event 1, 2, 3 or 4 interlock function is not used.	oFF

¹ Parameters related to multi-memory area function

Operation mode

Symbol	Name	Data range	Factory set value
RA	PID/AT transfer	on: Autotuning (AT) oFF: PID control	oFF
ST	Startup tuning (ST)	on1: Execute one * on2: Execute always oFF: ST unused * When the Startup tuning is finished, the setting will automatically returns to "oFF: ST unused." The Startup tuning function (ST) is executed when the power is turned on; when transferred from STOP to RUN; or when the Set value (SV) is changed. This screen is not displayed when the control action is Position proportioning PID control.	oFF
HR	Automatic temperature rise learning	on: Learning * oFF: Unused * When the Automatic temperature rise learning is finished, the setting will automatically returns to "oFF: Unused." This screen is not displayed when set the Automatic temperature rise group to "0."	on
R-n	Auto/Manual transfer	AUTO: Auto mode MAN: Manual mode	AUTO
r-L	Remote/Local transfer	LoC: Local mode rEM: Remote mode	LoC
r-S	RUN/STOP transfer	rUn: RUN mode (Control start) SToP: STOP mode (Control stop)	rUn

Parameter setting mode

Symbol	Name	Data range	Factory set value
EV1	Event 1 set value (EV1) ¹	Deviation: -Input span to +Input span Process and set value:	50
EV2	Event 2 set value (EV2) ¹	Input scale low to Input scale high Manipulated output value (MV1 or MV2):	50
EV3	Event 3 set value (EV3) ¹	-5.0 to +105.0%	50
EV4	Event 4 set value (EV4) ¹	Not displayed when Event function is not used. EV4 is not displayed when the Event 4 is used as an LBA.	50
LbR	Control loop break alarm (LBA) time ¹	1 to 7200 seconds, oFF: Unused This screen is displayed when the Event 4 is used as an LBA.	480
LbD	LBA deadband ¹	0 to Input span This screen is displayed when the Event 4 is used as an LBA.	0
P	Proportional band ¹ [heat-side]	TC/RTD inputs: 0 (0.0, 0.0) to Input span ² (Unit: °C [°F]) Voltage (V)/Current (I) inputs: 0.0 to 1000.0% of Input span 0 (0.0, 0.0): ON/OFF action	30 ^a
I	Integral time ¹ [heat-side]	PID control or Heat/Cool PID control: 1 to 3600 seconds or 0.1 to 1999.9 seconds oFF: PD action (both heat-side and cool-side) Position proportioning PID control: 1 to 3600 seconds or 0.1 to 1999.9 seconds	240
d	Derivative time ¹ [heat-side]	1 to 3600 seconds or 0.1 to 1999.9 seconds oFF: PI action	60
rPF	Control response parameter ¹	0: Slow 1: Medium 2: Fast [When the P or PD action is selected, this setting becomes invalid.]	Note 1
PC	Proportional band ^{1,3} [cool-side]	TC/RTD inputs: 1 (0.1, 0.01) to Input span (Unit: °C [°F]) Voltage (V)/Current (I) inputs: 0.1 to 1000.0% of Input span	30 ^a
IC	Integral time ^{1,3} [cool-side]	1 to 3600 seconds or 0.1 to 1999.9 seconds oFF: PD action (both heat-side and cool-side)	240
DC	Derivative time ^{1,3} [cool-side]	1 to 3600 seconds or 0.1 to 1999.9 seconds oFF: PI action	60
db	Overlap/Deadband ^{1,3}	TC/RTD inputs: -Input span to +Input span (Unit: °C [°F]) Voltage (V)/Current (I) inputs: -100.0 to +100.0% of Input span Minus (-) setting results in Overlap. However, the overlapping range is within the proportional range.	0 ^a
nr	Manual reset ¹	-100.0 to +100.0% The offset can be manually eliminated. The screen is displayed when the Integral time [heat-side] or Integral time [cool-side] is set to "oFF."	0.0
SRU	Setting change rate limiter (up) ¹	1 to Input span/unit time * oFF: Unused	oFF
SRD	Setting change rate limiter (down) ¹	* Unit time (factory set value): 60 seconds	oFF
RS	Area soak time ¹	0 minutes 00 seconds to 199 minutes 59 seconds or 0 hours 00 minutes to 99 hours 59 minutes Any Area soak time is set when Ramp/Soak control is performed. Data range of Area soak time can be selected on the Soak time unit.	0:00
LnRA	Link area number ¹	1 to 8 oFF: No link It is possible to perform Ramp/Soak control by linking each memory area. The memory area at the linked destination at that time is set.	oFF

¹ Parameters related to Multi-memory area function

² Data range varies depending on the Decimal point position

³ This screen is displayed when the control action is Heat/Cool PID control.

^a Factory set value varies depending on the instrument specification.

Note 1: PID control, Position proportioning PID control (0) Heat/Cool PID control (2)

Setup setting mode

Symbol	Name	Data range	Factory set value
HbR1	Heater break alarm 1 (HBA1) set value ^{a,b}	When CT is CTL-6-P-N: 0.1 to 30.0 A oFF: Not used When CT is CTL-12-S56-10L-N: 0.1 to 100.0 A oFF: Not used	oFF
HbL1	Heater break determination point 1 ^{a,b,c}	0.1 to 100.0% of HBA1 set value oFF: Heater break determination is invalid	30.0
HbH1	Heater melting determination point 1 ^{a,b,c}	0.1 to 100.0% of HBA1 set value oFF: Heater melting determination is invalid	30.0
HbR2	Heater break alarm 2 (HBA2) set value ^{d,e}	When CT is CTL-6-P-N: 0.1 to 30.0 A oFF: Not used When CT is CTL-12-S56-10L-N: 0.1 to 100.0 A oFF: Not used	oFF
HbL2	Heater break determination point 2 ^{d,e,f}	0.1 to 100.0% of HBA2 set value oFF: Heater break determination is invalid	30.0
HbH2	Heater melting determination point 2 ^{d,e,f}	0.1 to 100.0% of HBA2 set value oFF: Heater melting determination is invalid	30.0
Pb	PV bias	-Input span to +Input span	0
dF	PV digital filter	0.1 to 100.0 seconds oFF: Unused	oFF

^a Displayed when the CT1 is provided.

^b This screen is not displayed when set the CT1 assignment to "0: None."

^c Displayed when the HBA1 type is type B.

^d Displayed when the CT2 is provided.

^e This screen is not displayed when set the CT2 assignment to "0: None."

^f Displayed when the HBA2 type is type B.

Symbol	Name	Data range	Factory set value																																																							
Pr	PV ratio	0.500 to 1.500	1.000																																																							
PLC	PV low input cut-off	0.00 to 25.00% of input span This screen is displayed when the Square root extraction is set to "1: Used."	0.00																																																							
rb	RS bias	-Input span to +Input span	0																																																							
dF2	RS digital filter	0.1 to 100.0 seconds oFF: Unused	oFF																																																							
rr	RS ratio	0.001 to 9.999	1.000																																																							
f	Proportional cycle time [heat-side]	0.1 to 100.0 seconds This screen is not displayed when the output type is Voltage/Current output.	20.0 ^a																																																							
l	Proportional cycle time [cool-side]	0.1 to 100.0 seconds Displayed only when the control action is Heat/Cool PID control. This screen is not displayed when the output type is Voltage/Current output.	20.0 ^a																																																							
Rdd1	Device address 1 ^b	0 to 99 Do not use the same device address for more than one controller in multi-drop connection. In Modbus communication, two-way communication is not possible when the address is 0.	0																																																							
bPS1	Communication speed 1 ^b	2.4: 2400 bps 4.8: 4800 bps 9.6: 9600 bps 19.2: 19200 bps 38.4: 38400 bps	19.2																																																							
bF1	Data bit configuration 1 ^b	<table border="1"> <thead> <tr> <th rowspan="2">Data</th> <th colspan="3">Bit configuration</th> </tr> <tr> <th>Stop</th> <th>Parity</th> <th></th> </tr> </thead> <tbody> <tr> <td>8n1</td> <td>8</td> <td>1</td> <td>Without</td> </tr> <tr> <td>8n2</td> <td>8</td> <td>2</td> <td>Without</td> </tr> <tr> <td>8E1</td> <td>8</td> <td>1</td> <td>Even</td> </tr> <tr> <td>8E2</td> <td>8</td> <td>2</td> <td>Even</td> </tr> <tr> <td>8o1</td> <td>8</td> <td>1</td> <td>Odd</td> </tr> <tr> <td>8o2</td> <td>8</td> <td>2</td> <td>Odd</td> </tr> <tr> <td>7n1*</td> <td>7</td> <td>1</td> <td>Without</td> </tr> <tr> <td>7n2*</td> <td>7</td> <td>2</td> <td>Without</td> </tr> <tr> <td>7E1*</td> <td>7</td> <td>1</td> <td>Even</td> </tr> <tr> <td>7E2*</td> <td>7</td> <td>2</td> <td>Even</td> </tr> <tr> <td>7o1*</td> <td>7</td> <td>1</td> <td>Odd</td> </tr> <tr> <td>7o2*</td> <td>7</td> <td>2</td> <td>Odd</td> </tr> </tbody> </table> <p>* When the Modbus communication protocol selected, this setting becomes invalid.</p>	Data	Bit configuration			Stop	Parity		8n1	8	1	Without	8n2	8	2	Without	8E1	8	1	Even	8E2	8	2	Even	8o1	8	1	Odd	8o2	8	2	Odd	7n1*	7	1	Without	7n2*	7	2	Without	7E1*	7	1	Even	7E2*	7	2	Even	7o1*	7	1	Odd	7o2*	7	2	Odd	8n1
Data	Bit configuration																																																									
	Stop	Parity																																																								
8n1	8	1	Without																																																							
8n2	8	2	Without																																																							
8E1	8	1	Even																																																							
8E2	8	2	Even																																																							
8o1	8	1	Odd																																																							
8o2	8	2	Odd																																																							
7n1*	7	1	Without																																																							
7n2*	7	2	Without																																																							
7E1*	7	1	Even																																																							
7E2*	7	2	Even																																																							
7o1*	7	1	Odd																																																							
7o2*	7	2	Odd																																																							
Inf1	Interval time 1 ^b	0 to 250 ms	10																																																							
Rdd2	Device address 2 ^c	Same as the Device address 1	0																																																							
bPS2	Communication speed 2 ^{c,d}	Same as the Communication speed 1	19.2																																																							
bF2	Data bit configuration 2 ^{c,d}	Same as the Data bit configuration 1	8n1																																																							
Inf2	Interval time 2 ^{c,d}	Same as the Interval time 1	10																																																							
LC	Set lock level	0: Unlock 1: Lock Set to "0" or "1" for each digit.	0000																																																							

^a Factory set value varies depending on the instrument specification.

^b Displayed only when the Communication 1 is provided.

^c Displayed only when the Communication 2 is provided.

^d This screen is not displayed when the Intercontroller communication function is selected.





Engineering mode

Parameters in Engineering mode are settable only when the controller is in STOP mode. However, it is possible to check only the data even in RUN mode. In addition, there are invalid parameters when no optional function is specified.

Symbol	Name	Data range	Factory set value
F10	Function block 10	This is first parameter symbol of Function block 10.	
SPCH	STOP display	0: "SToP" is displayed on the PV display. 1: "SToP" is displayed on the SV display.	1
dE	Bar graph display	0: No display 4: Deviation value 1: MV 5: CT1 input value 2: PV 6: CT2 input value 3: SV monitor	1
dEUR	Bar graph display resolution	1 to 100 digit/dot The resolution can be changed when the Bar graph display (dE) was set to deviation value or CT input value.	100
dSoP	PV flashing display at input error	0: Flashing display 1: Non-flashing display	0
F11	Function block 11	This is first parameter symbol of Function block 11.	
Fn1	Direct key 1	0: Unused 1: AM transfer key (Type 1, Type 2)	1
Fn2	Direct key 2	0: Unused 1: MONI key (For type 1) or R/L transfer key (For type 2)	1
Fn3	Direct key 3	0: Unused 1: AREA key (For type 1) or RUN/STOP transfer key (For type 2)	1
Fn	Direct key type	1: Type 1 2: Type 2	1

Symbol	Name	Data range	Factory set value
F21	Function block 21	This is first parameter symbol of Function block 21.	
InP	Input type	0: TC input K 1: TC input J 2: TC input R 3: TC input S 4: TC input B 5: TC input E 6: TC input N 7: TC input T 8: TC input W5Re/W26Re 9: TC input PLII 10: TC input U 11: TC input L 12: RTD input Pt100 13: RTD input JPt100 14: Current input 0 to 20 mA DC 15: Current input 4 to 20 mA DC 16: Voltage (high) input 0 to 10 V DC 17: Voltage (high) input 0 to 5 V DC 18: Voltage (high) input 1 to 5 V DC 19: Voltage (low) input 0 to 1 V DC 20: Voltage (low) input 0 to 10 mV DC 21: Voltage (low) input ±1 V DC 22: Voltage (low) input ±100 mV DC 23: Voltage (low) input ±10 mV DC	0 ^a
UnI	Display unit	0: °C 1: °F Use to select the temperature unit for Thermocouple (TC) and RTD inputs.	0
PGDP	Decimal point position	0: No decimal place 1: One decimal place 2: Two decimal places 3: Three decimal places 4: Four decimal places TC input: K, J, E: Only 0 or 1 can be set. T, U, L: Only 1 can be set. Other than the above: Only 0 can be set. RTD input: From 0 to 2 can be set. V/I inputs: From 0 to 4 can be set.	0 ^a
PGSH	Input scale high	TC/RTD inputs: Input scale low to Maximum value of the selected input range Voltage (V)/Current (I) inputs: -19999 to +19999 (Varies with the setting of the Decimal point position)	Maximum value of the selected input range ^a
PGSL	Input scale low	TC/RTD inputs: Minimum value of the selected input range to Input scale high Voltage (V)/Current (I) inputs: -19999 to +19999 (Varies with the setting of the Decimal point position)	Minimum value of the selected input range ^a
POH	Input error determination point (high)	Input scale low - (5% of input span) to Input scale high + (5% of input span)	Input scale high + (5% of input span) ^a
POL	Input error determination point (low)	Input scale low - (5% of input span)	Input scale low - (5% of input span) ^a
boS	Burnout direction	0: Upscale 1: Downscale Valid only when the TC input and Voltage (low) input are selected.	0
SQR	Square root extraction	0: Unused 1: Used	0
PFr9	Power supply frequency	0: 50 Hz 1: 60 Hz If the display on the screen flickers, set the value to the same value as the power frequency used. No power frequency can be changed while it can be normally measured with the CT input and/or the power feed forward input provided.	0
SnP	Sampling cycle	0: 50 ms 1: 100 ms 2: 250 ms	1
F22	Function block 22	This is first parameter symbol of Function block 22.	
rInP	Remote setting input type	Refer to the input type (InP) for the transfer method of the voltage (low) or voltage (high) input. 14: 0 to 20 mA DC 15: 4 to 20 mA DC 16: 0 to 10 V DC 17: 0 to 5 V DC 18: 1 to 5 V DC 19: 0 to 1 V DC 20: 0 to 100 mV DC 21: 0 to 10 mV DC	15 ^a
F23	Function block 23	This is first parameter symbol of Function block 23.	
dI5L	Digital input (DI) assignment	1 to 8 (Refer to next page table 1.)	1
F30	Function block 30	This is first parameter symbol of Function block 30.	
LoGL	Output assignment	1 to 7 (Refer to next page table 2.)	2
oFF1	Timer 1	0.0 to 600.0 seconds	0.0
oFF2	Timer 2	Customization tool is necessary when the timer function is available.	0.0
oFF3	Timer 3		0.0
oFF4	Timer 4		0.0
EUC	Energized/De-energized	0: Energized 1: De-energized	0000

^a Factory set value varies depending on the instrument specification.

Symbol	Name	Data range	Factory set value
RLC1	Alarm (ALM) lamp lighting condition 1	0: ALM lamp is not lit 1: ALM lamp is lit  The ALM lamp is lit through the OR operation of EV1 to EV4 each of which is set to "1: ALM lamp is lit."	1111
RLC2	Alarm (ALM) lamp lighting condition 2	0: ALM lamp is not lit 1: ALM lamp is lit 	0011
SS	Output status at STOP mode	0: OFF 1: Action continued 	0000
F33	Function block 33	This is first parameter symbol of Function block 33.	
Ro	Transmission output type	0: None 5: MV2 [cool-side] 1: PV 6: SV 2: SV monitor 7: Remote setting 3: Deviation value (RS) input value 4: MV1 [heat-side]	1
RHS	Transmission output scale high	When the PV, SV, SV monitor and RS: Input scale low to Input scale high When the MV1 and MV2: -5.0 to +105.0 %	Input scale high
RLS	Transmission output scale low	When the deviation value: -Input span to +Input span	Input scale low
F41	Function block 41	This is first parameter symbol of Function block 41.	
ES1	Event 1 type	0: None 1: Deviation high ¹ 2: Deviation low ¹ 3: Deviation high/low ¹ 4: Band ¹ 5: Process high ¹ 6: Process low ¹ 7: SV high 8: SV low 9: Unused 10: MV1 high [heat-side] ^{1,2} 11: MV1 low [heat-side] ^{1,2} 12: MV2 high [cool-side] ¹ 13: MV2 low [cool-side] ¹ ¹ Event hold action is available. ² Feedback resistance (FBR) input value is displayed when the control motor with Feedback resistance (FBR) is used.	0 ^a
EH01	Event 1 hold action	0: OFF 2: Re-hold action ON 1: Hold action ON	0 ^a
E1L1	Event 1 interlock	0: Unused 1: Used	0
EH1	Event 1 differential gap	Deviation, process or set value: 0 to Input span MV: 0.0 to 110.0 %	2 ^a
EHF1	Event 1 delay timer	0.0 to 600.0 seconds	0.0
EE01	Force ON of Event 1 action	0: Invalid 1: Valid 	0000
F42	Function block 42	This is first parameter symbol of Function block 42.	
ES2	Event 2 type	Same as Event 1 type	
EH02	Event 2 hold action	Same as Event 1 hold action	
E1L2	Event 2 interlock	Same as Event 1 interlock	
EH2	Event 2 differential gap	Same as Event 1 differential gap	
EHF2	Event 2 delay timer	Same as Event 1 delay timer	
EE02	Force ON of Event 2 action	Same as Force ON of Event 1 action	
F43	Function block 43	This is first parameter symbol of Function block 43.	
ES3	Event 3 type	Same as Event 1 type	
EH03	Event 3 hold action	Same as Event 1 hold action	
E1L3	Event 3 interlock	Same as Event 1 interlock	
EH3	Event 3 differential gap	Same as Event 1 differential gap	
EHF3	Event 3 delay timer	Same as Event 1 delay timer	
EE03	Force ON of Event 3 action	Same as Force ON of Event 1 action	
F44	Function block 44	This is first parameter symbol of Function block 44.	
ES4	Event 4 type	9: Control loop break alarm (LBA) The other data is the same as an Event 1 type.	

^a Factory set value varies depending on the instrument specification.

Symbol	Name	Data range	Factory set value
EH04	Event 4 hold action	Same as Event 1 hold action	
E1L4	Event 4 interlock	Same as Event 1 interlock	
EH4	Event 4 differential gap	Same as Event 1 differential gap The invalidity in case of the LBA.	
EHF4	Event 4 delay timer	Same as Event 1 delay timer	
EE04	Force ON of Event 4 action	Same as Force ON of Event 1 action	
F45	Function block 45	This is first parameter symbol of Function block 45.	
CFR1	CT1 ratio	0 to 9999 CT type: CTL-6-P-N CTL-12-S56-10L-N	800 ^a
CFR1	CT1 assignment	0: None 1: OUT1 2: OUT2 3 to 6: Do not set this one	1
HbS1	Heater break alarm 1 (HBA1) type	0: Heater break alarm 1 (HBA1) type A 1: Heater break alarm 1 (HBA1) type B	0 ^a
HbC1	Number of heater break alarm 1 (HBA1) delay times	0 to 255	5
F46	Function block 46	This is first parameter symbol of Function block 46.	
CFR2	CT2 ratio	Same as CT1 ratio	
CFR2	CT2 assignment	0: None 1: OUT1 2: OUT2 3 to 6: Do not set this one	0
HbS2	Heater break alarm 2 (HBA2) type	0: Heater break alarm 2 (HBA2) type A 1: Heater break alarm 2 (HBA2) type B	0
HbC2	Number of heater break alarm 2 (HBA2) delay times	Same as Number of heater break alarm 1 (HBA1) delay times	
F50	Function block 50	This is first parameter symbol of Function block 50.	
Pd	Hot/Cold start	0: Hot start 1 1: Hot start 2 2: Cold start 3: Stop start	0
PdR	Start determination point	0 to Input span (The unit is the same as input value.) (0: Action depending on the Hot/Cold start selection)	3 % of input span
CRn	External input type	0: Remote setting input 1: Intercontroller communication cascade control 2: Intercontroller communication ratio setting	0
nCH	Master channel selection	0 to 31 This value is valid when Intercontroller communication cascade control or ratio setting is selected.	0
FrP	SV tracking	0: Unused 1: Used	1
nHFS	MV transfer function [Action taken when changed to Manual mode from Auto mode]	0: MV1 or MV2 in Auto mode is used. 1: When selected by Digital input (DI): MV1 or MV2 in previous Manual mode is used. When selected by front key: MV1 or MV2 in Auto mode is used. 2: MV1 or MV2 in previous Manual mode is used.	0
PHFS	PV transfer function	0: Unused 1: Used	0
F51	Function block 51	This is first parameter symbol of Function block 51.	
oS	Control action	0: Brilliant II PID control (direct action) 1: Brilliant II PID control (reverse action) 2: Brilliant II Heat/Cool PID control [water cooling] 3: Brilliant II Heat/Cool PID control [air cooling] 4: Brilliant II Heat/Cool PID control [Cooling gain linear type] 5: Brilliant II Position proportioning PID control (reverse action) 6: Brilliant II Position proportioning PID control (direct action)	1 ^a
IddP	Integral/Derivative time decimal point position	0: 1 second setting (No decimal place) 1: 0.1 seconds setting (One decimal place)	0
dGR	Derivative gain	0.1 to 10.0	6.0
oHH	ON/OFF action differential gap (upper)	TC/RTD inputs: 0.0 to Input span (Unit: °C [°F])	1 ^a
oHL	ON/OFF action differential gap (lower)	Voltage (V)/Current (I) inputs: 0.0 to 100.0 % of input span	1 ^a
RoHE	Action (high) at input error	0: Normal control	0
RuHE	Action (low) at input error	1: Manipulated output value at input error	0
P5n	Manipulated output value at input error	-105.0 to +105.0 %	0.0
rnh1	Manipulated output value (MV1) at STOP mode	-5.0 to +105.0 %	-5.0
rnh2	Manipulated output value (MV2) at STOP mode		-5.0
orU	Output change rate limiter (up) [MV1]	0.0 to 100.0 %/seconds (0.0: OFF)	0.0
ord	Output change rate limiter (down) [MV1]		0.0

^a Factory set value varies depending on the instrument specification.

Symbol	Name	Data range	Factory set value
oLH	Output limiter high (MV1)	Output limiter low (MV1) to 105.0 %	105.0
oLL	Output limiter low (MV1)	-5.0 % to Output limiter high (MV1)	-5.0
orU2	Output change rate limiter (up) [MV2]	Same as Output change rate limiter (up) [MV1]	0.0
ord2	Output change rate limiter (down) [MV2]	Same as Output change rate limiter (down) [MV1]	0.0
oLH2	Output limiter high (MV2)	Output limiter low (MV2) to 105.0 %	105.0
oLL2	Output limiter low (MV2)	-5.0 % to Output limiter high (MV2)	-5.0
PFf	Power feed forward selection	0: Unused 1: Used	1
PFfS	Power feed forward gain	0.01 to 5.00	1.00
dFP	Derivative action	0: Measured value derivative 1: Deviation derivative	0
US	Undershoot suppression factor	0.000 to 1.000	1.000 ^a
dbPR	Overlap/Deadband reference point	0.0 to 1.0	0.0
F52	Function block 52	This is first parameter symbol of Function block 52.	
RFb	AT bias	-Input span to +Input span	0
RFc	AT cycles	0: 1.5 cycles 1: 2.0 cycles 2: 2.5 cycles 3: 3.0 cycles	1
RFH	AT differential gap time	0.0 to 50.0 seconds	10.0
RFon	Output value with AT turned on	Output value with AT turned off to 105.0 %	105.0
RFof	Output value with AT turned off	-105.0 % to Output value with AT turned on	-105.0
PLH	Proportional band limiter (high) [heat-side]	TC/RTD inputs: 0 (0.0, 0.00) to Input span ^b (Unit: °C [°F]) Voltage (V)/Current (I) inputs: 0.0 to 1000.0 % of input span	Input span ^a
PLL	Proportional band limiter (low) [heat-side]		0 ^a
ILH	Integral time limiter (high) [heat-side]	0 to 3600 seconds or 0.0 to 1999.9 seconds (Varies with the setting of the Integral/Derivative time decimal point position)	3600
ILL	Integral time limiter (low) [heat-side]		0
dLH	Derivative time limiter (high) [heat-side]		3600
dLL	Derivative time limiter (low) [heat-side]		0
PcLH	Proportional band limiter (high) [cool-side]	TC/RTD inputs: 1 (0.1, 0.01) to input span ^b (Unit: °C [°F]) Voltage (V)/Current (I) inputs: 0.1 to 1000.0 % of input span	Input span ^a
PcLL	Proportional band limiter (low) [cool-side]		1 ^a
icLH	Integral time limiter (high) [cool-side]	Same as Integral time limiter (high) [heat-side]	3600
icLL	Integral time limiter (low) [cool-side]	Same as Integral time limiter (low) [heat-side]	0
dcLH	Derivative time limiter (high) [cool-side]	Same as Derivative time limiter (high) [heat-side]	3600
dcLL	Derivative time limiter (low) [cool-side]	Same as Derivative time limiter (low) [heat-side]	0
PRJ	Proportional band adjusting factor [heat-side]	0.01 to 10.00	1.00
IRJ	Integral time adjusting factor [heat-side]		1.00
DRJ	Derivative time adjusting factor [heat-side]		1.00
PCRJ	Proportional band adjusting factor [cool-side]		1.00
ICRJ	Integral time adjusting factor [cool-side]		1.00
DCRJ	Derivative time adjusting factor [cool-side]		1.00
F53	Function block 53	This is first parameter symbol of Function block 53.	
ydb	Open/Close output neutral zone	0.1 to 10.0 % of output	2.0
yHS	Open/Close output differential gap	0.1 to 5.0 % of output	1.0
ybr	Action at feedback resistance (FBR) input error	0: Action depending on the valve action at STOP 1: Control action continued	0
PaS	Feedback adjustment	At the Feedback adjustment screen, press the shift key for 5 seconds to start the adjustment.	—
noF	Control motor time	5 to 1000 seconds	10
oLR	Integrated output limiter	0.0 to 200.0 % of control motor time 0.0: Integrated output limiter function OFF This value becomes invalid when Feedback resistance (FBR) input is used.	150.0
YRL	Valve action at STOP	0: Close-side output OFF, Open-side output OFF 1: Close-side output ON, Open-side output OFF 2: Close-side output OFF, Open-side output ON	0
YRSO	Action at saturated output	0: Invalid 1: Valid	0

^a Factory set value varies depending on the instrument specification.

^b Data range varies depending on the Decimal point position

Symbol	Name	Data range	Factory set value
F54	Function block 54	This is first parameter symbol of Function block 54.	
ST	ST start condition	0: Activate the Startup tuning (ST) function when the power is turned on; when transferred from STOP to RUN; or when the Set value (SV) is changed. 1: Activate the Startup tuning (ST) function when the power is turned on; or when transferred from STOP to RUN. 2: Activate the Startup tuning (ST) function when the Set value (SV) is changed.	0
STPB	ST proportional band adjusting factor	0.01 to 10.00 times	1.00
STIT	ST integral time adjusting factor		1.00
STDT	ST derivative time adjusting factor		1.00
F55	Function block 55	This is first parameter symbol of Function block 55.	
CHR0	Automatic temperature rise group	0 to 16 (0: Automatic temperature rise function OFF)	0
rSG	RUN/STOP group	0 to 16 (0: RUN/STOP group function OFF)	0
CHRd	Automatic temperature rise dead time	0.1 to 1999.9 seconds	10.0
CHRf	Automatic temperature rise gradient data	0.1 to Input span/minutes	1.0
F60	Function block 60	This is first parameter symbol of Function block 60.	
CRP1	Communication 1 protocol	0: RKC communication 1: Modbus	0 ^a
CRP2	Communication 2 protocol	0: RKC communication 1: Modbus 2: Intercontroller communication	2
F70	Function block 70	This is first parameter symbol of Function block 70.	
SHrT	Setting change rate limiter unit time	1 to 3600 seconds	60
STDP	Soak time unit	0: 0 hours 00 minutes to 99 hours 59 minutes 1: 0 minutes 00 seconds to 199 minutes 59 seconds	1
F71	Function block 71	This is first parameter symbol of Function block 71.	
SLH	Setting limiter high	Setting limiter low to Input scale high	Input scale high
SLL	Setting limiter low	Input scale low to Setting limiter high	Input scale low
F91	Function block 91	This is first parameter symbol of Function block 91.	
C277	ROM version monitor	Display the version of loaded software.	—
OT	Integrated operating time monitor	0 to 19999 hours	—
FLD	Holding peak value ambient temperature monitor	-10.0 to +100.0 °C	—
HEFR	Power feed forward input value monitor	0.0 to 160.0 % Display in the percentage of the load voltage (rated value).	—

^a Factory set value varies depending on the instrument specification.

Table 1: Digital input (DI) assignment

Set value	DI 1	DI 2	DI 3	DI 4	DI 5	DI 6	DI 7		
1	Memory area number selection (1 to 8)	Memory area set *	Memory area set *	Memory area set *	Memory area set *	Memory area set *	Unused		
2							Unused		
3							RUN/STOP	REMLOC	AUTOMAN
4							Unused	Unused	Unused
5							REMLOC	AUTOMAN	Interlock release
6							RUN/STOP	Unused	Interlock release
7							REMLOC	Unused	Interlock release
8							AUTOMAN	Unused	Interlock release

RUN/STOP: RUN/STOP transfer AUTOMAN: Auto/Manual transfer REMLOC: Remote/Local transfer

* Only when ZK-1165 specification was specified, memory area transfer is possible without area set input. For memory area transfer by ZK-1165 specification, refer to **ZK-1165 Specification (IMR01W08-ED)**.

Table 2: Output assignment

"Energized" or "De-energized" can be selected for the Digital outputs (DO 1 to DO 4).

[However, with the exception of "FAIL" ("De-energized" fixed)]

This setting is conducted in Engineering mode.

Set value	OUT1	OUT2	DO1	DO2	DO3	DO4
1	MV1	MV2	EV1	EV2	EV3	EV4
2	MV1	MV2	EV1	EV2	EV3	HBA1, HBA2
3	MV1	MV2	EV1	EV2	HBA1, HBA2	FAIL
4	MV1	MV2	EV1	HBA1, HBA2	EV3	EV4
5	MV1	HBA1, HBA2	EV1	EV2	EV3	EV4
6	MV1	HBA1, HBA2	EV1	EV2	EV3	FAIL
7	MV1	FAIL	EV1	EV2	EV3	EV4

MV1: Control output 1, MV2: Control output 2, HBA1: Heater break alarm 1, HBA2: Heater break alarm 2,

FAIL: Fail output (De-energized only), EV1 to EV4: Event output 1 to Event output 4

– When used as Heat/Cool PID control or Position proportioning PID control, select any code of 1 to 4.

– An output logic becomes OR output when two or more output functions are assigned to one output.